

DWFRS 002/12



Risk Assessments

[Request a review](#)



[Back](#)

Risk Assessment Number: DWFRS 002/12

Version:

2

Risk Assessment Manager:

[Request A Review](#)

Activity/Equipment being assessed:	W&F: Storage of foam concentrate stocks
Reason for assessment:	Other
Risk Assessment Status:	Live
Directorate:	Service Support
Team:	
Date Original RA Created:	4/18/12
Date Original Published:	4/19/12
Review Last Created Date:	1/4/23
Date Last Review Published:	1/4/23

[Hazard Screening](#)

[Risk Assessment Matrix](#)

[Attachments/Comments](#)

[Health & Safety Section](#)

Hazards

The hazards that apply are:

Hazardous Substance

Manual Handling Assessment:

No

[Back](#)

[Request A Review](#)



Risk Assessments

[Request a review](#)[Back](#)**Risk Assessment Number:** DWFRS 002/12**Version:** 2**Risk Assessment Manager:** [REDACTED][Request A Review](#)

Activity/Equipment being assessed: W&F:Storage of foam concentrate stocks
Reason for assessment: Other
Risk Assessment Status: Live
Directorate: Service Support
Team:
Date Original RA Created: 4/18/12
Date Original Published: 4/19/12
Review Last Created Date: 1/4/23
Date Last Review Published: 1/4/23

[Hazard Screening](#)[Risk Assessment Matrix](#)[Attachments/Comments](#)[Health & Safety Section](#)

Hazard Assessments

							Previous	1	Next
Task	Haz. No.	Hazard & Associated Harm/Loss	Risk Group	Existing Controls	Severity	Likelyhood	Risk Rating		
Storage of plastic drums of foam concentrate on fire stations	1	Spillage of fluid from ruptured drums causing damage to the environment	[DFRS, ENV]	Sealed, manufacturers drums of no more than 25 litres. EA packs held at each location. Trained staff.	2	2	4		
Storage of plastic drums of foam concentrate on fire stations	1	Spillage of fluid from ruptured drums causing damage to the environment	[DFRS, ENV]	Sealed, manufacturers drums of no more than 25 litres. EA packs held at each location. Trained staff.	2	2	4		
Transfer of foam from storage drums into tanks or extinguishers.	2	Contamination of personnel and property	[FDO, FF, FGS, GA, MS, PROP]	EA kit on appliances, Trained staff, PPE, small manufacturers storage drums	1	3	3		
Transfer of foam from storage drums into tanks or extinguishers.	2	Contamination of personnel and property	[FDO, FF, FGS, GA, MS, PROP]	EA kit on appliances, Trained staff, PPE, small manufacturers storage drums	1	3	3		
							Previous	1	Next



Risk Assessments

[Request a review](#)



[Back](#)

Risk Assessment Number: DWFRS 002/12

Version: 2

Risk Assessment Manager: [REDACTED]

[Request A Review](#)

Activity/Equipment being assessed:	W&F: Storage of foam concentrate stocks
Reason for assessment:	Other
Risk Assessment Status:	Live
Directorate:	Service Support
Team:	
Date Original RA Created:	4/18/12
Date Original Published:	4/19/12
Review Last Created Date:	1/4/23
Date Last Review Published:	1/4/23

[Hazard Screening](#)

[Risk Assessment Matrix](#)

[Attachments/Comments](#)

[Health & Safety Section](#)

Attachments/Comments

File Name

[Back](#)

[Request A Review](#)



Risk Assessments

Request a review



Back

Risk Assessment Number: DWFRS 002/12

Version: 2

Risk Assessment Manager: [REDACTED]

[Request A Review](#)

Activity/Equipment being assessed:	W&F: Storage of foam concentrate stocks
Reason for assessment:	Other
Risk Assessment Status:	Live
Directorate:	Service Support
Team:	
Date Original RA Created:	4/18/12
Date Original Published:	4/19/12
Review Last Created Date:	1/4/23
Date Last Review Published:	1/4/23

[Hazard Screening](#) [Risk Assessment Matrix](#) [Attachments/Comments](#) [Health & Safety Section](#)

Comments:
Audit Date:
Audit Results:

[Back](#)

[Request A Review](#)